Evidence of Performance

Resistance to wind load
Watertightness
Air permeability
Operating forces, Mechanical properties
Load-bearing capacity of safety devices

Test Report 102 33372/2e (ITT)

Client	Cuhadaroglu metal sanayi ve pazarlama a.s. Yakuplu Köyü Yolu 34900 B.Cekmece Istanbul Turkey
Product	Single tilt and turn window with fixed toplight and sidelight
Designation	ST 70
Overall dimensions (W x H)	2200 mm x 2200 mm
Frame material	Thermal break aluminium profiles
Special features	-/-

Resistance to wind load – EN 12210

Class C1 / B1

Watertightness – EN 12208

Class 9A

Air permeability – EN 12207

Class 4

Operating forces – EN 13115

Class 1

Mechanical properties – EN 13115

Class 4

Load-bearing capacity of safety devices

Requirement fulfilled

ift Rosenheim
6. November 2007


Jörn Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
ift Centre Windows & Facades

Robert Kolacny, Dipl.-Ing. (FH)
Test engineer
ift Centre Windows & Facades

Basis

EN 14351-1 : 2006-03, Windows and external doors – Product standard
Test standards:
EN 1026 : 2000-06
EN 1027 : 2000-06
EN 12211 : 2000-06
EN 12046-1 : 2003-11
EN 14608 : 2004-03
EN 14609 : 2004-03

Representation



Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1 : 2006-03; For the purpose of clarification it can be used as basis for the manufacturer ITT report summary for attestation of conformity procedure 3 as the basis for the manufacturer declaration.

Validity

The data and results refer solely to the tested and described specimen.

Subject to compliance with the relevant casement weights, the test results can be extrapolated for constructions of identical or smaller dimensions of the same design, type of rebate and similar format.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

Notes on publication

The **ift**-Guidance Sheet "Conditions and Guidance for the Use of **ift** test Documents" applies..

The cover sheet can be used as abstract.

Contents

The report contains a total of 22 pages

ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkannte PÜZ-Stelle: BAY 18
DAP-PL-0808.99
DAP-ZE-2288.00
TGA-ZM-16-93-00
TGA-ZM-16-93-60