# Evidence of Performance

## Resistance to wind load
## Watertightness
## Air permeability
## Operating forces, Mechanical properties
## Load-bearing capacity of safety devices

### Test Report 102 33372/3e (ITT)

| | |
|---|---|
| Client | Cuhadaroglu<br>metal sanayi ve pazarlama a.s.<br>Yakuplu Köyü Yolu<br><br>34900 B.Cekmece Istanbul<br>Turkey |
| Product | Single tilt and turn window with fixed toplight and sidelight |
| Designation | ST 80 |
| Overall dimensions (W x H) | 2200 mm x 2200 mm |
| Frame material | Thermal break aluminium profiles |
| Special features | -/- |

Resistance to wind load – EN 12210

Class C2 / B2

Watertightness – EN 12208

Class 9A

Air permeability – EN 12207

Class 4

Operating forces – EN 13115

Class 1

Mechanical properties – EN 13115

Class 4

Load-bearing capacity of safety devices

Requirement fulfilled

**ift** Rosenheim
6. November 2007


Jörn Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
ift Centre Windows & Facades

Robert Kolacny, Dipl.-Ing. (FH)
Test engineer
ift Centre Windows & Facades

**Basis**

EN 14351-1 : 2006-03, Windows and external doors – Product standard
Test standards men:
EN 1026 : 2000-06
EN 1027 : 2000-06
EN 12211 : 2000-06
EN 12046-1 : 2003-11
EN 14608 : 2004-03
EN 14609 : 2004-03

**Representation**



**Instruction for use**

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1 : 2006-03; For the purpose of clarification it can be used as basis for the manufacturer ITT report summary for attestation of conformity procedure 3 as the basis for the manufacturer declaration.

**Validity**

The data and results refer solely to the tested and described specimen.

Subject to compliance with the relevant casement weights, the test results can be extrapolated for constructions of identical or smaller dimensions of the same design, type of rebate and similar format.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

**Notes on publication**

The **ift**-Guidance Sheet "Conditions and Guidance for the Use of **ift** test Documents" applies..

The cover sheet can be uses an abstract.

**Contents**

The report contains a total of 22 pages



**ift** Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkannte PÜZ-Stelle: BAY 18
DAP-PL-0808.99
DAP-ZE-2288.00
TGA-ZM-16-93-00
TGA-ZM-16-93-60